



## Telephone Call or Visit Record

USEPA SF



1270074

LDWSF 12.3.56

06/10/98

COMPANY <b>Longview fiber</b>		Permit/DA No. <b>7693</b>	Date/Year <b>6/10/98</b>
Contact <b>Sunny Bivens</b>	Office/Address <b>2 Marginal</b>		Time <b>200</b> <input checked="" type="checkbox"/> a.m. <input checked="" type="checkbox"/> p.m.
Metro Employee <b>B &amp; SJ</b>	Office	Telephone No.	
<input type="checkbox"/> Telephone	<input type="checkbox"/> Conversation	<input type="checkbox"/> Action	
<input type="checkbox"/> Incoming Call	<input type="checkbox"/> Outgoing Call		
SUBJECT <b>Sample site inspection / new P.T. system install</b>			
SUMMARY <b>Met with Sunny their new systems is working well and they are zero discharge most of the time they installed a Beckart System (Chem flocculation) w/ filter presses and are able to reuse the water back into their starch making. They are on track to produce around 20 ton/month of Ink solids (last year they shipped off w/ Sk only 4-55 gal drum of ink sludge). Told him that he would be an Ideal Candidate for Inverness award</b>			
Action Required <b>Permit is currently in draft that have been delivered since they are initially zero and the flow totals are too high, I will not</b>			
Action Taken <b>Issue A final and possibly reissue A zero discharge permit (no refund of permit fee)</b>			
<input type="checkbox"/> Continued on Back			

(10/92)

**no need for compliance sampling monitoring fee section**